

# Ozone Impacts of Diesel Particulate Filters in DFW: Project Number E6

Presentation to the TERC  
Science Advisory Committee  
February 21, 2008


Greg Yarwood and Lit Chan  
ENVIRON International Corporation

[gyarwood@environcorp.com](mailto:gyarwood@environcorp.com)

# Outline

- **Many diesel engines use DOCs and catalyzed DPFs to meet stringent PM emissions standards**
- **DOC/DPF potentially creates excess NO<sub>2</sub> emissions that impact ozone & PM nitrate formation**
- **EPA's findings showed baseline NO<sub>2</sub> fraction of NO<sub>x</sub> was 6%, increased to 26% to 34% for DPF-equipped trucks**
- **Ozone impacts of excess NO<sub>2</sub> emissions may be especially problematic in the urban core of DFW area**

# Diesel Particulate Filters (DPFs)



- **DPF traps PM from engine exhaust, and regenerates by oxidizing PM at high temperature**
- **Active regeneration (e.g. plug in electric or fuel injection) or passive regeneration (e.g. catalyzed DPF)**

# Catalyzed DPFs

- **Variety of strategies are used for continuous passive regeneration**
- **Most common is to place a Diesel Oxidation Catalyst (DOC) upstream of DPF or use catalyzed DPF**
  - **Converts exhaust NO to NO<sub>2</sub>**
  - **Exhaust NO<sub>2</sub> assists soot combustion by acting as oxidizing agent for soot, and lowering catalyst “light-off” temperature**
  - **Excess NO<sub>2</sub> remaining after soot oxidation increases exhaust NO<sub>2</sub>/NO<sub>x</sub> ratio**

# Catalyzed DPFs – Excess NO<sub>2</sub>

- EPA found NO<sub>2</sub> emissions from DPFs can increase over baseline by 20% to 28% of total NO<sub>x</sub>
- MECA Studies also found that catalyzed DPFs emit excess NO<sub>2</sub> and recommended mitigation strategies
- CARB currently limits DPF *retrofit* devices to increase exhaust NO<sub>2</sub> to a max of 30% of total NO<sub>x</sub> mass starting Jan 2007, and 20% after Jan 2009
- EPA has not identified any specific compliance requirements for DPFs or DOCs with respect to NO<sub>2</sub> emissions

**MECA: Manufacturers of Emission Controls Association**

# Ozone Impact of Excess NO<sub>2</sub>



- **Shifting chemical form of emitted NO<sub>x</sub> from NO to NO<sub>2</sub> reduces amount of ozone titrated by fresh NO emissions**
  - **Increase ozone in urban core**
  - **Enable more rapid ozone production downwind of urban core**

## Excess NO<sub>2</sub> Concern – DFW Area


- **Ozone impacts of excess NO<sub>2</sub> emissions most problematic when emissions are concentrated and occur in an area where ozone formation is inhibited by high NO<sub>x</sub> concentrations, as in the urban core of DFW**
- **Large fleets of HD diesel vehicles and off-road engines used in construction and other industries**

# Project Suggestion

- **Evaluate ozone impacts of excess NO<sub>2</sub> from DPFs using the June 2005 ozone episode developed for DFW in TERC project H60**
- **Project Objective – To show whether excess NO<sub>2</sub> emissions from DPFs will hamper progress toward attaining ozone standard in DFW and other parts of Texas**

# H60 Model for DFW

- June 18-23, 2005
  - 2009 future year available
- Stagnation period with winds progressing from northeasterly to southerly
- MM5 meteorology by TAMU
- Emissions by TCEQ/ENVIRON
  - Mobile sources based on NCTCOG travel demand model
  - Detailed information for HDDVs



# Project Approach

- **TCEQ emissions inventory will be used for fleet characteristics of on-road HD diesel engines and off-road diesel equipment categories**
- **Estimate of penetration rates of DPFs into these fleets**
- **Latest findings from EPA- and CARB-sponsored studies/reports will be used to quantify effect of DPFs on NO<sub>2</sub>/NO<sub>x</sub> ratio of emissions**
- **Develop several scenarios for excess NO<sub>2</sub> emissions in several future years (e.g., 2012 and 2018)**

## Project Approach (cont.)

- **Conduct ozone modeling to evaluate the ozone impacts of DPFs for 2009 future year**
  - **Actual penetration of DPFs by 2009 will be limited by slow fleet turnover of heavy-duty diesels**
  - **Conduct sensitivity tests to evaluate how significant the ozone impacts of DPFs could ultimately become**
  - **Sensitivity tests also will investigate whether excess NO<sub>2</sub> emissions produce different magnitudes of ozone impacts in urban vs. rural environments**

## Expected Benefits/Policy Relevance

- TERC Strategic Research Plan: “Special attention should be given to mobile sources since they contribute a large portion of NO<sub>x</sub> and VOC emission”
- Diesel particulate filters are being *utilized now* in new heavy-duty diesel vehicles
- Demonstrate whether excess NO<sub>2</sub> emissions from DPFs will hamper progress toward attaining the ozone standard in DFW and other parts of Texas.

# Emission Benefits of Advances in Low-NOx Burner Technology

Charles Benson, ENVIRON Boston

[cbenson@environcorp.com](mailto:cbenson@environcorp.com)

Steve Ramsey, ENVIRON Houston

[sramsey@environcorp.com](mailto:sramsey@environcorp.com)

# Advanced Burner Design

- **Manufacturers continuously refine burner designs**
  - Lean premixed combustion, staged fuel combustion and flue gas recirculation are the preferred control strategies
  - Prototype burners in test furnaces have achieved NO<sub>x</sub> levels as low as 5 ppm
  - Current commercial burners can achieve NO<sub>x</sub> levels about 20-50% below those of the prior generation of burners (2001)
- **Process heaters:**
  - Key suppliers of advanced burner designs include Zeeco, John Zink and Callidus Technologies
  - NO<sub>x</sub> emissions of 10-15 ppm have been achieved in commercial applications
  - Reductions in burner diameter and flame length have improved retrofitting
- **Boilers:**
  - Key suppliers of advanced burner designs include TODD Combustion and COEN
  - Suppliers have guaranteed NO<sub>x</sub> levels as low as 9 ppm

# Advanced Burner Performance

Category	Current HGB ESADs (30 TAC 117.310(a))	Potential Emission Reductions with Commercially Available Burner Technologies
Gas-fired Boilers (≥ 100 MMBtu/hour)	0.020 lb/MMBtu	20-50%
Gas-fired Boilers (40-100 MMBtu/hour)	0.030 lb/MMBtu	20-50%
Gas-fired Boilers (< 40MMBtu/hour)	0.036 lb/MMBtu	20-50%
Process Heaters (≥ 40 MMBtu/hour)	0.025 lb/MMBtu	20-50%
Process Heaters (< 40MMBtu/hour)	0.036 lb/MMBtu	20-50%

# ENVIRON Project Concept

- Approach:
  - Determine achievable NOx emission limits by emission source category for combustion retrofits using state of the art, commercially available technologies
  - Define current HGB combustion inventory performance:
    - NOx control plans
    - ECT-1 Annual Compliance Reports
    - Facility surveys
  - Estimate reduction in emissions and costs of control if state of the art combustion technologies were applied to the HGB inventory
- Project cost range: \$100K - \$150K
- Refine analysis by working with a limited number of facilities to develop more robust emissions and cost data (Phase II)

# Q & A